



Licking County Health Department
 Ohio School Inspection Program
 675 Price Road
 Newark, OH 43055
 740-349-6535

Recommendations Notice

Assessment Date: 3/11/2008

Assessor: Herman Lacy, R.S.

Facility: Licking Valley Middle School

Physical Address: 1379 Licking Valley Rd.
 Newark, OH 43055

Primary Contact: Rick Nabors

Facility Contact:

Facility Type: Middle School

Other Facility Info:

Reason for Assessment
 Routine

Area/Topic

Subtopic	Priority	Assessment Standard	Problem Description/Corrective Action	Room/ Location	Due Date
1. Grounds and Building Exterior					
1.2 Bus and Vehicle Use Areas					
	4	1.2.1 Schools shall abide by the engine-idling time policies developed in accordance with rule 3301.83.20 (O) of the Ohio Administrative Code.	No signs posted at bus loading zone stating this is a "No Idle Zone". Post signs in bus loading/unloading areas		9/7/2008
1.3 Sidewalks and Walkways					
	4	1.3.1 Vehicle use areas, including bus loading and unloading areas, and pedestrian walkways shall be clearly marked.	Student walkways are not marked for loading/unloading buses. Mark walkways for students to use to load/unload on buses.		9/7/2008
1.11 Roof					

Area/Topic

Subtopic	Priority Assessment Standard	Problem Description/Corrective Action	Room/ Location	Due Date
4	<p>1.11.1 The roof of a school shall be inspected by a qualified individual once a year, following severe weather, as determined by the school, and when otherwise deemed necessary. Severe weather means any weather event that could damage the roof or lead to water intrusion including, but not limited to, damaging wind, hail, lightning, ice damming or heavy rain. Qualified individual, as used in this paragraph, means an individual familiar with the design, installation and maintenance of roofing systems. If the heating, ventilating and air conditioning system is located on the roof, the qualified individual must also be familiar with the operation and maintenance of the heating, ventilating and air conditioning system or this system must be inspected by a differently qualified individual. The school shall have documentation for the sanitarian at the time of the inspection that includes the following:</p> <p>(i) A current drawing of the roof that indicates the location of all roof top items of interest including:</p> <ul style="list-style-type: none">(a) Heating, Ventilation and Air Conditioning unit(s);(b) Exhaust vents notated with type and height of stack; <p>and</p> <ul style="list-style-type: none">(c) Roof drains. <p>(ii) A copy of the Ohio Department of Health Roof Inspection Form for each inspection conducted since the last inspection by the board of health.</p>	<p>No drawing of roof available at time of my inspection. Provide a drawing of roof that shows locations of heating, ventilation, and air conditioning units, exhaust vents notated with the type and height of stack and roof drains.</p>		9/7/2008

Area/Topic

Subtopic	Priority	Assessment Standard	Problem Description/Corrective Action	Room/ Location	Due Date
	4	<p>1.11.1 The roof of a school shall be inspected by a qualified individual once a year, following severe weather, as determined by the school, and when otherwise deemed necessary. Severe weather means any weather event that could damage the roof or lead to water intrusion including, but not limited to, damaging wind, hail, lightning, ice damming or heavy rain. Qualified individual, as used in this paragraph, means an individual familiar with the design, installation and maintenance of roofing systems. If the heating, ventilating and air conditioning system is located on the roof, the qualified individual must also be familiar with the operation and maintenance of the heating, ventilating and air conditioning system or this system must be inspected by a differently qualified individual. The school shall have documentation for the sanitarian at the time of the inspection that includes the following:</p> <p>(i) A current drawing of the roof that indicates the location of all roof top items of interest including:</p> <p>(a) Heating, Ventilation and Air Conditioning unit(s);</p> <p>(b) Exhaust vents notated with type and height of stack; and</p> <p>(c) Roof drains.</p> <p>(ii) A copy of the Ohio Department of Health Roof Inspection Form for each inspection conducted since the last inspection by the board of health.</p>	Roof has not been inspected annually. Have a qualified individual inspect roof every year.		9/7/2008
3. Solid Waste Disposal Area					
3.1 Trash Recycling and Compactor Containers					
	4	3.1.3 Trash and recycling containers shall be equipped with lids and the lids shall cover the containers when not in use.	Dumpster out back has lids missing. Provide lids on dumpster		9/7/2008
5. Exterior Entrances and Exits					
5.1 Floor Mats					
	4	5.1.1 There shall be a five-step or fifteen foot walk off mat at all entry points into the building. If the area cannot accommodate a fifteen foot mat, the mat should be as long as the area will accommodate.	There are no 5 step or 15' walk off mats at school entry points-provide 5-step or 15' walk-off mats at entry points.		9/7/2008
9. Visual Arts Rooms					
9.1 General Safety and Security					
	4	9.1.1 All doors to the classroom shall be locked when the classroom is not occupied.	Doors to the visual arts classrooms were not locked at the time of my school inspection-the classrooms were not occupied. Lock all doors when classrooms are not occupied.		9/7/2008
17. Restrooms					

Area/Topic

Subtopic	Priority	Assessment Standard	Problem Description/Corrective Action	Room/ Location	Due Date
17.1 Sinks and Plumbing Fixtures	4	17.1.5 Hand-washing posters shall be visible from all sinks.	There are no handwashing posters at sinks in girls and boys restrooms by the gym. Provide handwashing signs at sinks in girl's and boy's restrooms		9/7/2008
17.3 Exhaust Fans	4	17.3.1 Exhaust fans shall be operable and continually operating while the building is occupied.	Exhaust fans do not work properly in the girls and boys restrooms by the gym. Repair exhaust fans so they will work properly		9/7/2008
19. Mechanical Rooms					
19.3 Housekeeping	4	19.3.1 There shall be no storage of items that inhibit or restrict routine maintenance or cleaning.	There are items under the vent in boiler room that makes it impossible to clean properly. Remove all items immediately.		9/7/2008
21. Healthcare Areas					
21.1 General	4	21.1.4 Locked storage for medications as required by section 3313.713 of the Revised Code, except when other law allows for the carrying and self administration of medication by the student.	Medication storage was not locked at the time of my inspection. Keep all medications locked.	Health Care Area	9/7/2008
21.2 Equipment and Durable Supplies	4	21.2.2 A sharps container must be present when sharps disposal is necessary.	No sharps container in healthcare room. Provide sharps container.		9/7/2008
22. Administrative Areas					
22.1 EH&S Management Policies	4	22.2.12 INTEGRATED PEST MANAGEMENT PLAN (IPM). Schools shall have a written IPM plan that includes identification of pests and conditions that attract pests; prevention techniques such as sanitation, vacuuming, structural repair and sealing; monitoring; education and training; approved least toxic chemical use only as a last resort; and pre-notification of chemical use.	There is no Integrated Pest Management Plan in place. Provide and IPM plan.		9/7/2008

Area/Topic

Subtopic

Priority Assessment Standard

Problem Description/Corrective Action

**Room/
Location**

Due Date

Herman Lacy, R.S.
Public Health Sanitarian