



**Licking County Health Department**  
 Ohio School Inspection Program  
 675 Price Road  
 Newark, OH 43055  
 740-349-6535

## Recommendations Notice

**Assessment Date:** 3/12/2008  
**Assessor:** Herman Lacy, R.S.  
**Facility:** Licking Valley High School  
**Physical Address:** 100 Hainsview Dr.  
 Newark, OH 43055

**Primary Contact:** Wes Weaver  
**Facility Contact:**  
**Facility Type:** High School  
**Other Facility Info:**

**Reason for Assessment**  
 Routine

**Area/Topic**

| Subtopic  | Priority | Assessment Standard  | Problem Description/Corrective Action  | Room/<br>Location | Due Date |
|---|----------|--|--|-------------------|----------|
| <b>1. Grounds and Building Exterior</b>                   |          |  |  |                   |          |
| <b>1.1 All School Grounds</b>                             |          |  |  |                   |          |
|   | 4        | 1.1.1 No trip hazards shall be present and grounds shall be maintained in a clean, orderly, and sanitary condition with no litter.             | There are scrap tires on ground by the athletic storage facility. Remove scrap tires from the premises. This will prevent mosquito breeding. |                   | 9/8/2008 |
| <b>1.2 Bus and Vehicle Use Areas</b>                      |          |  |  |                   |          |
|   | 4        | 1.2.1 Schools shall abide by the engine-idling time policies developed in accordance with rule 3301.83.20 (O) of the Ohio Administrative Code. | No signs posted at bus loading zone stating this is a "No Idle Zone"-Post signs in bus loading/unloading areas.                              |                   | 9/8/2008 |
| <b>1.3 Sidewalks and Walkways</b>                         |          |  |  |                   |          |
|   | 4        | 1.3.1 Vehicle use areas, including bus loading and unloading areas, and pedestrian walkways shall be clearly marked.                           | Bus loading and unloading areas are not marked clearly. Mark all areas for students to load/unload buses.                                    |                   | 9/8/2008 |
| <b>1.6 Gutters, Downspouts, Scuppers and Storm Drains</b> |          |  |  |                   |          |
|   | 4        | 1.6.1 Gutters, downspouts, scuppers and storm drains shall be properly connected and shall show no signs of obstruction.                       | No gutter drains and downspouts on athletic storage facility. Provide gutters and downspouts.  |                   | 9/8/2008 |
| <b>1.11 Roof</b>  |          |  |  |                   |          |

**Area/Topic**

| <b>Subtopic</b>                        | <b>Priority</b> | <b>Assessment Standard</b>   | <b>Problem Description/Corrective Action</b>   | <b>Room/ Location</b> | <b>Due Date</b> |
|--|-----------------|--|--|-----------------------|-----------------|
|  | 4               | <p>1.11.1 The roof of a school shall be inspected by a qualified individual once a year, following severe weather, as determined by the school, and when otherwise deemed necessary. Severe weather means any weather event that could damage the roof or lead to water intrusion including, but not limited to, damaging wind, hail, lightning, ice damming or heavy rain. Qualified individual, as used in this paragraph, means an individual familiar with the design, installation and maintenance of roofing systems. If the heating, ventilating and air conditioning system is located on the roof, the qualified individual must also be familiar with the operation and maintenance of the heating, ventilating and air conditioning system or this system must be inspected by a differently qualified individual. The school shall have documentation for the sanitarian at the time of the inspection that includes the following:</p> <p>(i) A current drawing of the roof that indicates the location of all roof top items of interest including:</p> <p>(a) Heating, Ventilation and Air Conditioning unit(s);</p> <p>(b) Exhaust vents notated with type and height of stack; and</p> <p>(c) Roof drains.</p> <p>(ii) A copy of the Ohio Department of Health Roof Inspection Form for each inspection conducted since the last inspection by the board of health.</p> | At the time of inspection, no drawing of school roof was available. Provide drawing at next inspection.                      |                       | 9/8/2008        |
| <b>5. Exterior Entrances and Exits</b> |                 |  |  |                       |                 |
| <b>5.1 Floor Mats</b>                  |                 |  |  |                       |                 |
|  | 4               | 5.1.1 There shall be a five-step or fifteen foot walk off mat at all entry points into the building. If the area cannot accommodate a fifteen foot mat, the mat should be as long as the area will accommodate.  | There are no 5-step or 15' walk off mats at all entry points into the building. Provide mats.                                |                       | 9/8/2008        |
| <b>6. All Indoor Environments</b>      |                 |  |  |                       |                 |
| <b>6.3 Pests</b>                       |                 |  |  |                       |                 |
|  | 4               | 6.3.1 There shall be no evidence of pests or obvious food sources for pests .  | There is trash and paper in the athletic storage facility. Remove all trash and papers, eliminating insect-rodent harborage. |                       | 9/8/2008        |
| <b>6.11 Ceilings</b>                   |                 |  |  |                       |                 |
|  | 4               | 6.11.1 Ceilings shall be present, intact and sanitary with no water damage, stains, suspected mold or chipping or peeling paint.   | There are signs of water leaks. Repair leaks and replace stained ceiling tiles.  | Band Hallway          | 9/8/2008        |
|  | 4               | 6.11.1 Ceilings shall be present, intact and sanitary with no water damage, stains, suspected mold or chipping or peeling paint.   | There are signs of water leaks. Repair leaks and replace stained ceiling tiles.  | Science Rooms         | 9/8/2008        |

**Area/Topic**

| <b>Subtopic</b>                          | <b>Priority</b> | <b>Assessment Standard</b>  | <b>Problem Description/Corrective Action</b>   | <b>Room/<br/>Location</b> | <b>Due Date</b> |
|--|-----------------|---|--|---------------------------|-----------------|
|  | 4               | 6.11.1 Ceilings shall be present, intact and sanitary with no water damage, stains, suspected mold or chipping or peeling paint.  | There are signs of water leaks. Repair leaks and replace stained ceiling tiles.  | Library                   | 9/8/2008        |
| <b>8. Science Rooms and Laboratories</b> |                 |   |  |                           |                 |
| <b>8.1 General Safety</b>                |                 |   |  |                           |                 |
|  | 4               | 8.1.1 All doors to the science classroom shall be locked when the classroom is not occupied.  | Doors to all science rooms were unlocked at time of my inspection. Classroom was unoccupied. Keep all doors locked when classrooms are not occupied. |                           | 9/8/2008        |
|  | 4               | 8.1.3 Master gas shutoff valve shall be clearly labeled, easily accessible in the classroom and immediately operable by staff.<br><br>Regulation. OAC Code Reference: 3701-54-08(A)(3)  | Master gas shutoff valve not marked in science rooms. Mark all master gas shutoff clearly.   |                           | 9/8/2008        |
| <b>9. Visual Arts Rooms</b>              |                 |   |  |                           |                 |
| <b>9.10 Emergency Equipment</b>          |                 |   |  |                           |                 |
|  | 4               | 9.10.1 Eyewash stations shall be operational, unobstructed and located within ten seconds of all work stations. Eyewash stations shall have at least fifteen minutes of continuous water flow with adequate pressure and be capable of flushing both eyes simultaneously. Documentation that eyewash stations have been tested monthly shall be available upon inspection. Elementary school art classrooms, where there is art instruction for only elementary school students, are exempt from the requirement for an eyewash station.<br><br>Refer to section 8.10.1 for more information about eyewash stations | There is no eyewash stations in the visual arts classrooms. Provide eyewash stations.  |                           | 9/8/2008        |
| <b>10. Industrial Arts Rooms</b>         |                 |   |  |                           |                 |
| <b>10.11 Emergency Equipment</b>         |                 |   |  |                           |                 |
|  | 4               | 10.11.2 Emergency showers and eyewash stations shall be operational, unobstructed and located within ten seconds of all workstations. Eyewash stations shall have at least fifteen minutes of continuous water flow with adequate pressure and shall be capable of flushing both eyes simultaneously. Documentation that emergency showers and eyewash stations have been tested monthly shall be available upon inspection.<br><br>Please refer to Section 8.10 for more information on emergency showers and eyewash stations.  | There are no emergency showers and eyewash stations in the industrial arts classrooms. Provide emergency showers and eyewash stations immediately.   |                           | 9/8/2008        |
| <b>16. Indoor Athletic Facilities</b>    |                 |   |  |                           |                 |
| <b>16.4 Locker Rooms</b>                 |                 |   |  |                           |                 |

**Area/Topic**

| <b>Subtopic</b>                          | <b>Priority</b> | <b>Assessment Standard</b>  | <b>Problem Description/Corrective Action</b>  | <b>Room/<br/>Location</b> | <b>Due Date</b> |
|--|-----------------|---|---|---------------------------|-----------------|
|  | 4               | 16.4.5 Operational showers used by students shall have non-slip mats or non-slip surfacing in the vicinity of showers where wet floors may pose a slip hazard.                            | There are no non-slip mats or non-slip surfacing in shower area for boys and girls locker rooms. Provide mats or surfacing. |                           | 9/8/2008        |
| <b>22. Administrative Areas</b>          |                 |   |   |                           |                 |
| <b>22.1 EH&amp;S Management Policies</b> |                 |   |   |                           |                 |
|  | 4               | 22.2.2 RADON TESTING. The school shall have a radon rule or protocol and evidence that the school has been built radon resistant or has been tested for radon within the past five years. | There is no evidence that school has been tested for Radon. Have school tested for radon every 5 years.                     |                           | 9/8/2008        |

---

Herman Lacy, R.S.  
Public Health Sanitarian