



Licking County Health Department

Ohio School Inspection Program

675 Price Road

Newark, OH 43055

740-349-6535

Recommendations Notice

Assessment Date: 3/10/2008

Assessor: Herman Lacy, R.S.

Facility: Licking Valley Elementary

Physical Address: 1510 Licking Valley Rd
Newark, OH 43055

Primary Contact: Tod Carmer

Facility Contact:

Facility Type: Elementary School

Other Facility Info:

Reason for Assessment

Routine

Area/Topic

Subtopic	Priority	Assessment Standard	Problem Description/Corrective Action	Room/Location	Due Date
1. Grounds and Building Exterior					
1.2 Bus and Vehicle Use Areas					
	4	1.2.2 No vehicles or gas-powered equipment shall idle near outside air intakes, entrances or exits or where buses are loading and unloading students.	Buses idling at loading time at entrances to the building. Have bus drivers shut off bus engines if they idle more than 5 minutes.		9/6/2008
	4	1.2.1 Schools shall abide by the engine-idling time policies developed in accordance with rule 3301.83.20 (O) of the Ohio Administrative Code.	No signs posted at school bus loading/unloading zones stating this is a "No Idle Zone". Post "No Idle Zone" signs in bus loading/unloading areas.		9/6/2008
1.3 Sidewalks and Walkways					
	4	1.3.1 Vehicle use areas, including bus loading and unloading areas, and pedestrian walkways shall be clearly marked.	Student walkways for bus loading and unloading areas are not marked. Mark all student walkways to loading and unloading areas for buses.		9/6/2008
1.9 Outside Air Intakes					
	4	1.9.1 There shall be no contaminant sources near outside air intakes and air intakes shall be protected by screens, louvers or other filtering devices.	Milk truck delivering milk was idling beside the outside air intake to school. Post "No Idle Zone" sign.		9/6/2008
3. Solid Waste Disposal Area					
3.1 Trash Recycling and Compactor Containers					
	4	3.1.2 Trash, recycling and compactor containers and surrounding areas shall be clean and located away from outdoor air intakes.	Dumpster located beside air intake to building. Move dumpster to another location away from air intakes.		9/6/2008

Area/Topic

Subtopic	Priority	Assessment Standard	Problem Description/Corrective Action	Room/ Location	Due Date
5. Exterior Entrances and Exits					
5.1 Floor Mats					
	4	5.1.1 There shall be a five-step or fifteen foot walk off mat at all entry points into the building. If the area cannot accommodate a fifteen foot mat, the mat should be as long as the area will accommodate.	There are no five step or 15' walk off mats at entry points into the building. Provide 5 step or 15' walk off mats at all entry points to the building.		9/6/2008
6. All Indoor Environments					
6.7 Portable Tables, Furniture and Shelving					
	4	6.7.1 Portable banquet tables, cafeteria tables and other portable furniture items, when not in a position intended for use, shall be stored in a manner that is inaccessible to students or shall be secured to the wall or floor to prevent injuries from tipping. Heavy furniture items shall be moved only by authorized personnel.	Cafeteria tables not stored in room intended for them. Remove items so tables can be stored in event storage room. This will make cafeteria tables inaccessible to the students.		9/6/2008
6.12 Windows					
	4	6.12.1 Window panes and frames shall be clean, intact and properly caulked or sealed and glazed.	In the intermediate upstairs hallway, the window pane is separate from the window frame. Repair or replace.		9/6/2008
9. Visual Arts Rooms					
9.1 General Safety and Security					
	4	9.1.1 All doors to the classroom shall be locked when the classroom is not occupied.	The door to the visual arts room was unlocked at the time of my inspection; the classroom was not occupied. Keep classroom door locked when classroom is not being used.		9/6/2008
22. Administrative Areas					
22.1 EH&S Management Policies					
	4	22.2.2 RADON TESTING. The school shall have a radon rule or protocol and evidence that the school has been built radon resistant or has been tested for radon within the past five years.	The school has not been tested for Radon. Have school tested for radon every 5 years.		9/6/2008

Herman Lacy, R.S.
Public Health Sanitarian